

CERTIFICATE of Conformity

Registration No.: AK 50444445 0001

Report No.: 50281915 001

Holder: VIETNAM ELECTRIC CABLE
CORPORATION
70-72 Nam Ky Khoi Nghia str.
Nguyen Thai Binh ward,
Dist. 1 Ho Chi Minh city 70000
Vietnam

Product: Cables / Wires
(Electric Cables for Photovoltaic Systems)

Identification: Type Designation : H1Z2Z2-K 1X1,5...240mm²
CADIVI
Rated Voltage : DC 1,5kV
Max. Storage Temperature: +45°C
Min. Temperature for Installation and Handling: -25°C
Max. Temperature at Conductor: 120°C
Remark: Refer to test report 50281915 001 for details.

Tested acc. to: EN 50618:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date 22.08.2019

Certification Body

Bo Liu



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg